



Department policy/ directive: 22-0422

**TO: Inspection Staff, BUILDERS & CONTRACTORS active in the City of Stonecrest, GA**

Ref: Announcement of Administrative policy regarding TEMP-to-PERMANENT POWER Inspections  
Requirements, Effective May 1, 2022

In the interest of public safety, the following directive is being implemented to the scope of inspections to receive **TEMP-To-PERMANENT POWER** approval, in accordance with the standards of the NFPA 70 (National Electrical Code):

1. ELECTRICAL PANEL inspection, to account for compatibility of all circuit breaker-to-conductors (i.e., wire size, type & insulation type) is to be inspected, with panel cover off (but in premises/accounted for), before the electrical panel becomes energized, with ALL circuit breakers in place and connected to the applicable wiring. This includes identification of the 240 Volt breakers along with identification marking of heat strip sizes (in KW) on data plates of AHUs, and to identify which circuits feed Ranges, AC condensers, Water Heaters, etc.

2. SAFETY: Ongoing control of each electrical Panel to be energized (per Temp-To-Perm Power approval) is the Contractor's responsibility. Therefore, the premises shall have the ability to be secured and power sources which can cause electrocution shall be inaccessible and secured. Failure to comply with an administrative directive / policy shall result in an unapproved inspection and a subsequent re-inspection required.

Respectfully,

A handwritten signature in black ink, appearing to read "Joseph P Stapleton II".

Joseph P Stapleton II, ISBE, CBO

Chief Building Official