



Required Inspections for Stand Alone Electrical Permits

Inspections indicated (checked) are the required inspections based on the plan review results and your type of permit:

Electrical panel / service upgrades:

Electric meter inspection/ final inspection:

(Grounding, service feeder's conductors, panel location, meter enclosure service mast for overhead services and required arc fault breakers) once approved this will also serve as a final inspection.

New electrical circuits:

- Rough inspection of wiring, raceway fastening, protection of structure (hole drilling / notching)
- Final inspection (inspection of devices and luminaires for polarity, grounding, and location)

Hardwired appliances or Vehicle Charging Stations:

- Rough and final inspection:

Inspection of wiring polarity and grounding / raceway, breaker(s) amperage based on demand load. As approved, this will serve as both rough and final inspections.

Solar Panels.

Final inspection:

- Inspection of disconnect rating and location, labeling, grounding, and raceway type and fastening.

3120 Stonecrest Boulevard Suite 190
Stonecrest, Georgia 30038
770.224.0200

FAX: 470.299.4214

www.stonecrestga.gov